


# Woolen Mill Fan Company


## Installation Guide for Bodine 098 and 6144 DC Motors with Bodine 790 Speed Controller.

Please read the included Bodine data sheets thoroughly and consult the National Electric Code and any applicable local area codes BEFORE starting installation.

### Speed Controller to Motor Connection Diagram




### Motor Wiring to Bodine 790 Speed Controller




290 Woolen Mill Road  
New Park, PA 17352  
Tel/Fax 717-382-4754  
architecturalfans.com

# Woolen Mill Fan Company

## Motor Connections to Bodine 790 Speed Controller




## Ground Connection to Bodine 790 Speed Controller



290 Woolen Mill Road  
New Park, PA 17352  
Tel/Fax 717-382-4754  
architecturalfans.com

# Woolen Mill Fan Company

Bodine 790 Speed Controller Setup.



Set ACC pot fully CW.

098 Motor - Dip Switches 1,2,3,7,8 set to ON  
6144 Motor - Dip Switches 2,4,5,6,7,8 set to ON

Note ! Please verify Dip Switch settings are correct for installed motor type.

Note ! Removal of the 0790 Speed Controller 3 pin plug invalidates the Bodine warranty.

290 Woolen Mill Road  
New Park, PA 17352  
Tel/Fax 717-382-4754  
architecturalfans.com